Suzhou TRYBA Building Materials Technology Co., Ltd.

TEST REPORT

SCOPE OF WORK
135 Vinyl Sliding Door


REPORT NUMBER
260303003SHF-002

TEST DATE(S)
2026-03-10 - 2026-03-11

ORIGINAL ISSUE DATE
2026-03-20

PAGES
20

DOCUMENT CONTROL NUMBER
LFT-APAC-SHF-OP-10k(January 13, 2025)
© 2025 INTERTEK



Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch

Test Report

Statement

1.This report is invalid without company's special seal for testing on the assigned page.

2.This report is invalid without an authorized person's signature.

3.This report is invalid if altered.

4.Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Don't copy this report in partial without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.

5.This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

6.Except for the obligation, responsibility and liability (if any) for the appropriateness and professionality of afore-mentioned testing itself within the scope and amount of the testing fee received, Intertek does not and will not accept any other obligation or liability.

7.If the Client has any questions about the test results, Intertek B&C should be informed within the storage period of the samples. The sample storage period ends 5 working days after the offical report issue date. Samples of certification program are retained for the period required by the certification rules. The samples storage period shall be calculated according to the issue date of the original report in the case of quoting results and modifying reports.

8.Intertek B&C will service this report for the entire test record retention period. The test record retention period ends 6 years after this report original issue date. The test record retention period for certification program is 10 years. Test records and other pertinent project documentation will be retained for the entire test record retention period.

9.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch
Plant 5 & 11(4F), No. 6958 Daye Road, Fengxian District, Shanghai, China
Tel: +86 21-61136116 Fax: 021-61189921
Website: www.intertek.com

Test Report

Original Issue Date:	2026-03-20	Intertek Report No.	260303003SHF-002

Applicant:	Suzhou TRYBA Building Materials Technology Co., Ltd.
Applicant Address:	36th floor, Jinhe International Building, 35 Shishan Road, Huqiu District, Suzhou City
Attn:	Alisa
Manufacturer:	TRYBA (Shanghai) Window Co., Ltd.
Manufacturer Address:	No.38, Mingye Road, Sheshan Industrial Park, Songjiang District, Shanghai
Product Type:	Sliding Door
Product Model:	135
Primary product designator:	Class LC - PG25 - Size Tested 2200 × 2100 mm (86.61 × 82.68 in.) - SD
Optional secondary designator:	Positive Design Pressure = +1200 Pa (25.06 psf) Negative Design Pressure = -1200 Pa (25.06 psf) Water penetration resistance test pressure = 360 Pa (7.52 psf)
SUBJECT:	Performance testing

Product Information

Product Name	Model	Specification
135 Vinyl Sliding Door	135	2200mm(Width) x 2100mm(Height)
Sample ID	**Sample Amount**	**Sample Received Date**
S260303003SHF.002	1 Set	2026-03-03
Brand	**Sample Description**	
TRYBA	The sample was a completely assembled, glazed, functional product (including hardware) and fully operable, fitted in the test apparatus in accordance with documented instructions.	

Test Methods And Standards

Test Standard	ASTM E283/E283M-2019; ASTM E547-00(R2016); ASTM E330/E330M-2014(R2021); ASTM F842-17; AAMA/WDMA/CSA101/I.S.2/A440-22 Clause 8.3.1, Clause 8.3.5 and Clause 8.3.6.2
Specification Standard	AAMA/WDMA/CSA 101/I.S.2/A440-22 (NAFS 2022 - North American Fenestration Standard / Specification for Windows, Doors and Skylights) Clause 8.3.1, Clause 8.3.2, Clause 8.3.3, Clause 8.3.4, Clause 8.3.5 and Clause 8.3.6.2; CSA A440S1-25 Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440-22 Clause 5.3 and Clause 5.4
Test Conclusion	The results met AAMA/WDMA/CSA 101/I.S.2/A440-22 and CSA A440S1-25 requirements specified on Sliding Door, and the results were shown in the following page.

Note: 1.This report does not involve sampling. The report only reflects conformity of the tested items of the samples provided by the testing applicant. Representativeness and authenticity of the submitted samples are responsibilities of the testing applicant.
2. This test item was conducted in one of our multi-sites address of Plant 3-5, No. 6978 Daye Road, Fengxian District, Shanghai (No. 4-South Plant, No. 161 Litai Road).

Report Authorized

Name: Gio Liu
Title: Reviewer

Name: John Zhang
Title: Project Engineer

intertek
Total Quality. Assured.

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Test Items, Method and Results：

2 Test Result

Table 2 Test Result

Test Description	*Requirements (Class LC-PG25)*		*Results*		*Verdict*
2026/3/10					
Operating Force Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.1	Maximum force to initiate motion	155 N	Maximum force to initiate motion	117 N	Pass
	Maximum force to maintain motion	155 N	Maximum force to maintain motion	89 N	
	Maximum force to engage latches for Close sash	100 N	Maximum force to engage latches for Close sash	24 N	
Air Leakage Resistance Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.2 ASTM E283/E283M-2019	Maximum air leakage at+75 Pa	1.5 $L/s \cdot m^2$	Air leakage at +75 Pa	0.41 $L/s \cdot m^2$	Pass
	Maximum air leakage at-75 Pa	1.5 $L/s \cdot m^2$	Air leakage at -75 Pa	0.37 $L/s \cdot m^2$	
Water Penetration Resistance Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.3 ASTM E547-00 (R2016)	Minimum water pressure	180 Pa	Test Pressure	360 Pa	Pass
			After water sprayed for four cycles in 24 minutes at 360 Pa, no water penetration was observed.		
Uniform Load Deflection Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.4.2 ASTM E330/E330M-2014(R2021)	Minimum Design Pressure (DP)	1200 Pa	Design Pressure (DP)	+1200 Pa	Reported
			Maximum deflection at Stile	3.0 mm	
			Maximum deflection at Mullion	22.2 mm	
			Design Pressure (DP)	-1200 Pa	
			Maximum deflection at Stile	3.2 mm	
			Maximum deflection at Mullion	24.7 mm	

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Table 2 Test Result (Continued)

Test Description	*Requirements (Class LC-PG25)*		*Results*		*Verdict*
2026/3/10					
Uniform Load Structural Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.4.3 ASTM E330/E330M-2014 (R2021)	Minimum Structural Pressure (STP)	1800 Pa	Structural Pressure (STP)	+1800 Pa	Pass
			No significant breakage or damage after ultimate strength was released.		
			Maximum permanent deformation at Stile	0.7 mm	
			Maximum permanent deformation at Mullion	1.2 mm	
			Structural Pressure (STP)	-1800 Pa	
			No significant breakage or damage after ultimate strength was released.		
			Maximum permanent deformation at Stile	0.5 mm	
			Maximum permanent deformation at Mullion	1.5 mm	
2026/3/11					
Forced-entry Resistance Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.5 ASTM F842-17	Minimum Grade 10		Test Class	Grade 10	Pass
			During the test and upon removal of loads, all locking devices were remained engaged and could not entry.		
Deglazing Test AAMA/WDMA/CSA 101/I.S.2/A440-22, Clause 8.3.6.2	Load for vertical sash members	320 N	After test, the sample does not be damaged in any way that would inhibit normal operation and there was no glazing breakage.		Pass
	Load for other members	230 N			

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Appendix B: Test Data

B.1 Air Leakage Resistance Test – Test method ASTM E283/E283M-2019

Overall Area: 4.62 m^2

Table B.1 Test Data of Air Leakage Resistance Test

Infiltration rate (75 Pa)	0.41 $L/s \cdot m^2$	0.08 cfm/ft^2
Exfiltration rate (75 Pa)	0.37 $L/s \cdot m^2$	0.07 cfm/ft^2
Requirements (75 Pa): Maximum allowable leakage for Class LC Doors	1.5 $L/s \cdot m^2$	0.3 cfm/ft^2

The tested specimen met the requirements for Class LC Doors for Air Leakage Resistance Test as per AAMA/WDMA/CSA 101/I.S.2/A440-22.

Appendix B: Test Data

B.2 Water resistance test – Test method ASTM E547-00(R2016)

No water penetration occurred when the pressure was 360 Pa (7.52 psf).
After water sprayed for four cycles in 24 minutes at 360 Pa, no water penetration was observed.

Test result: Pmax = 360 Pa (7.52 psf).

The tested specimen met the requirements for Class LC-PG25 for Water Penetration Resistance Test as per AAMA/WDMA/CSA 101/I.S.2/A440-22.

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Appendix B: Test Data

B.3 Uniform Load Deflection Test – Test method ASTM E330/E330M-2014(R2021), Procedure A

Span length, L = 2000 mm Set Points (1-3)
Span length, L = 2000 mm Set Points (4-6)

Test Pressure (DP), P = 1200 Pa (25.06 psf)




Fig.8 Locations of Displacement Measuring Devices

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Table B.2 Test Data of Uniform Load Deflection Test

Member (mm)		Test Pressure (Pa)	Deflection (mm)			Maximum Deflection(mm)
Item	Span Length		1	2	3	
Stile	2000	+P = 1200	1.1	3.9	0.7	3.0
		0	0.1	0.1	0.1	<0.1
		-P = -1200	1.2	4.1	0.7	3.2
		0	<0.1	0.6	0.1	0.6
Member (mm)		Test Pressure (Pa)	Deflection (mm)			Maximum Deflection(mm)
Item	Span Length		4	5	6	
Mullion	2000	+P = 1200	2.2	24.1	1.7	22.2
		0	0.2	0.1	<0.1	<0.1
		-P = -1200	2.4	26.9	2.0	24.7
		0	0.3	1.1	0.1	0.9

Table B.3 Test Data of Uniform Load Deflection Test for Stile

Test Pressure	Deflection Measurements, mm (in.)			
	Positive		Negative	
	Maximum Deflection		Maximum Deflection	
1200 Pa (25.06 psf)	3.0	(0.12)	3.2	(0.13)
Span length, L = 2000 mm (78.74 in.)	Deflection limit: reported			

Table B.4 Test Data of Uniform Load Deflection Test for Mullion

Test Pressure	Deflection Measurements, mm (in.)			
	Positive		Negative	
	Maximum Deflection		Maximum Deflection	
1200 Pa (25.06 psf)	22.2	(0.87)	24.7	(0.97)
Span length, L = 2000 mm (78.74 in.)	Deflection limit: reported			

The tested specimen met the requirements for Class LC-PG25 for Uniform Load deflection Test at Design Pressure as per AAMA/WDMA/CSA 101/I.S.2/A440-22.

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Appendix B: Test Data

B.4 Uniform Load Structrual Test – Test method ASTM E330/E330M-2014(R2021), Procedure A

Design Pressure, P = 1200 Pa (25.06 psf)

Structural Pressure, P = 1800 Pa (37.59 psf)

Table B.5 Test Data of Uniform Load Structural Test

Member (mm)		Test Pressure (Pa)	Permanent deformation(mm)			Maximum permanent deformation(mm)
Item	Span Length		1	2	3	
Stile	2000	+P = 1800	–	–	–	–
		0	<0.1	0.7	<0.1	0.7
		-P = -1800	–	–	–	–
		0	<0.1	0.5	0.1	0.5
Permanent Deformation limit, L x 0.4% = 8.0 mm						
Member (mm)		Test Pressure (Pa)	Permanent deformation(mm)			Maximum permanent deformation(mm)
Item	Span Length		4	5	6	
Mullion	2000	+P = 1800	–	–	–	–
		0	0.1	1.3	0.2	1.2
		-P = -1800	–	–	–	–
		0	0.3	1.8	0.3	1.5
Permanent Deformation limit, L x 0.4% = 8.0 mm						

Table B.6 Test Data of Uniform Load Structural Test For Stile

Test Pressure	Deflection Measurements, mm (in.)			
	Positive		Negative	
	Perm. Set		Perm. Set	
1800 Pa (37.59 psf)	0.7	(0.03)	0.5	(0.02)

Table B.7 Test Data of Uniform Load Structural Test For Mullion

Test Pressure	Deflection Measurements, mm (in.)			
	Positive		Negative	
	Perm. Set		Perm. Set	
1800 Pa (37.59 psf)	1.2	(0.05)	1.5	(0.06)

After the test loads were released, there was no failure or permanent deformation of any part of the window system that would cause the test specimen to be inoperable. There was no permanent deformation which was in excess of 0.4% of its span.

The tested specimen met the requirements for Class LC-PG25 for Uniform Load Structure Test at Structural Pressure as per AAMA/WDMA/CSA 101/I.S.2/A440-22.

Test Report

Original Issue Date: 2026-03-20 Intertek Report No. 260303003SHF-002

Appendix C: Sample Received Photo



Revision:

NO.	Date	Changes
260303003SHF-002	2026-03-20	First issue